



Residential Water Metering Requirements for Pasadena Water and Power (“PWP”):

Senate Bill No. 7 (Housing: water meter: multiunit structures) approved by the Governor September 25, 2016, requires that individual meters or submeters be installed on all new multifamily residential units. Per Senate Bill No. 7: Each water purveyor that sells, leases, rents, furnishes, or delivers water service to a newly constructed multiunit residential structure or newly constructed mixed-use residential and commercial structure for which an application for a water connection, or more than one connection, is submitted after January 1, 2018, shall require a measurement of the quantity of water supplied to each individual residential dwelling unit as a condition of new water service. The law exempts long-term health care facilities, low-income housing, residential care facilities, housing at a place of education, and time-share properties, as well as, other multiunit residential structures deemed infeasible by the Department of Housing and Community Development.

Per the Water Regulations adopted by City Council on June 4, 2012: “The water service will end at the curb, public right of way or property line at the option of PWP. Where the location of the meter box or vault on the City side of the property line is not practicable, the meter box or vault shall be located on the Customer’s premises or such other location that may be agreed upon by PWP at its option. The Customer shall be responsible for the expense of installation and maintenance of the lines on the Customer’s side of the property line connecting to PWP’s service where construction of the Customer’s facilities began.”

The following submetering options are available for PWP customers:

Option 1:

Individual metering located on the parkway.

The Water Division will install individual water meters on the parkway in front of the project site, if permitted by available space as per the General Requirements, for each residential unit. The owner/developer shall install an approved double check valve backflow prevention assembly at each domestic water service. All dedicated irrigation services must have a Reduced Pressure Zone Valve Assembly (“RP”). The location of the backflow prevention assemblies shall be above ground within 20-feet of the property line, and the assemblies require registration and annual test certifications. PWP’s responsibility of service ends at the meter and PWP will bill each tenant directly.

Option 2:

Individual metering located on private property.

The Water Division will install a service lateral up to the property line with a shut off valve. The owner/developer shall provide and install an approved double check valve backflow prevention assembly after the shut off valve and will install all piping behind the property line. The location of the backflow prevention assembly shall be above ground within 20-feet of the property line, and the assembly requires registration and an annual test certification. The owner/developer will pay for and install all water meters, provided by PWP, to each residential unit. Water meters must be installed horizontally and must be located in an open area or in a garage/parking area and must have a minimum 12-inch above grade in order for meter readers to have unrestricted access to them if needed. All dedicated irrigation services must have a RP. PWP will inspect the individual meters as a condition of providing service. PWP’s responsibility of service ends at the property line and PWP will bill each tenant directly.



Option 3:

Submetering by third party vendor located on private property.

The Water Division will install master water meter(s) on the parkway, in front of the project site. The owner/developer must submit a statement on letterhead stating that a Contractor licensed by the California State License Board will install submeters, per Senate Bill No. 7, to all residential units. The owner/developer shall install an approved double check valve backflow prevention assembly on each submeter. All dedicated irrigation services must have a RP. The backflow prevention assemblies require registration and annual test certifications. PWP will inspect the submeters as a condition of providing service. PWP's responsibility of service ends at the master meter and the owner/developer is responsible for billing each tenant per Senate Bill No. 7.